



District Level Water Testing Laboratory
(Uttar Pradesh Jal Nigam, Pilibhit)

Address: Office of Executive Engineer, Construction Division,
U.P. Jal Nigam In front of district veterinary Hospital, Tanakpur road, Pilibhit, Pin- 262001

WATER ANALYSIS REPORT

Rept. No 5305 Date: 12.09.2025

Customer Details

Office Name and Address Guru Nanak Gurdas Academy, Bhopatpur Sakaria, Puranpur, Pilibhit.

Ref Letter No & Date Application by customer Date 10.09.2025

Sample Description

District	Pilibhit	Block	Puranpur
Gram Panchayat/Nagar Panchayat	Bhopatpur	Village/Ward No.	Bhopatpur
Habitation	Bhopatpur	Location	Guru Nanak Gurdas Academy
Water Source	Handpump	Sample Code	PIL/25/09/5305
Date & Time of Sample Collection	10.09.2025 09:40AM	Sample Collector Name	Deepak Joshi
Receiving Date & Time	10.09.2025 10.50AM	Sample Receiver	Sanjeev kumar
Water Sample Type	Drinking Water	Quantity of Sample	1000ml

Environmental Condition

Temperature	25°C ±2°C	Humidity	50% ±20%
Analysis Date	11.09.2025		

Technical Data of Analysis

Sr. No	Analyzed parameters (Unit of Measurement)	Observed Value	Unit	Specified Values as per BIS		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	Total Coliform	00	CFU	00	No relaxation	APHA 23 rd Edition :2017 (IS 10500)
2	E .Coli	00	CFU	00	No relaxation	APHA 23 rd Edition :2017 (IS 10500)

- Note 1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 48 hrs (in case of non perishable items only) from the date of issue of tests reports unless.

Microbiologist
U.P. JAL NIGAM (PILIBHIT)
Distt. Water Testing Lab. Analysis by
Survesh Kumar
Pilibhit Microbiologist

End of the Report